



Shenzhen Bontek Compliance Testing Laboratory Co., Ltd.

CE Certificate of Conformity

Certification number: BCT13HC-1499S

Report number: BCT13HR-1499S

Shenzhen Bontek Compliance Testing Laboratory Co., Ltd. hereby declares that testing has been completed and reports have been generated for:

Applicant: NORTEC SA DE CV

Address: Miguel Aleman B7, Col. Jardines de la Victoria, 67119 Guadalupe, Nuevo Leon, Mexico

Manufacturer: NORTEC SA DE CV

Address: Miguel Aleman B7, Col. Jardines de la Victoria, 67119 Guadalupe, Nuevo Leon, Mexico

Product: UNINTERRUPTIBLE POWER SUPPLY

Model: UPS-IND 1238, UPS-IND 1246

And, in accordance with the following applicable directives:

2006/95/EC Low Voltage Directive

That this product has been assessed against the following applicable standards;

LVD EN 62040-1:2008

Uninterruptible power systems (UPS) - Part 1: General and safety requirements for UPS

Therefore, Shenzhen Bontek Compliance Testing Laboratory Co., Ltd hereby acknowledges that the applicant may issue a DECLARATION of CONFORMITY and apply the CE marking in accordance with European Union Rules.

Attestation by:



Kendy Wang

Date of Issued: August 21, 2013

1/F, Block East H-3, OCT Eastern Ind. Zone, Qiaocheng East Road, Nanshan, Shenzhen, China
Tel:+86-755-86337020 Fax:86-755-86337028 <http://www.bontek.com.cn>



Attachment File For The BCT13HC-1499S

Model List

Model name	Input	Output
UPS-IND 1238	AC 220V, 60Hz, 37.5A DC 192V, 23A	AC 208/120V, 60Hz, 6KVA, 4.2KW
UPS-IND 1246	AC 220V, 60Hz, 51.5A DC 192V, 40.5A	AC 208/120V, 60Hz, 10KVA, 7KW

