



Shenzhen Bontek Compliance Testing Laboratory Co., Ltd.

CE Certificate of Conformity

Certification number: BCT13HC-1500S

Report number: BCT13HR-1500S

Shenzhen Bontek Compliance Testing Laboratory Co., Ltd. hereby declares that testing has been completed and reports have been generated for:

Applicant: **NORTEC SA DE CV**

Address: Miguel Aleman B7, Col. Jardines de la Victoria, 67119 Guadalupe, Nuevo Leon, Mexico

Manufacturer: **NORTEC SA DE CV**

Address: Miguel Aleman B7, Col. Jardines de la Victoria, 67119 Guadalupe, Nuevo Leon, Mexico

Product: **UNINTERRUPTIBLE POWER SUPPLY**

Model: **UPS-IND 1346, UPS-IND 1350, UPS-IND 1353,
UPS-IND 1358, UPS-IND 1362, UPS-IND 1366,
UPS-IND 1370, UPS-IND 1376, UPS-IND 1378**

And, in accordance with the following applicable directives:

2006/95/EC Low Voltage Directive

That this product has been assessed against the following applicable standards;

LVD

EN 62040-1:2008

Uninterruptible power systems (UPS) - Part 1: General and safety requirements for UPS

Therefore, Shenzhen Bontek Compliance Testing Laboratory Co., Ltd hereby acknowledges that the applicant may issue a DECLARATION of CONFORMITY and apply the CE marking in accordance with European Union Rules.

Attestation by:

Kendy Wang



Date of Issued: August 21, 2013

1/F, Block East H-3, OCT Eastern Ind. Zone, Qiaocheng East Road, Nanshan, Shenzhen, China
Tel: +86-755-86337020 Fax: +86-755-86337028 <http://www.bontek.com.cn>



Attachment File For The BCT13HC-1500S

Model List

Model name	Input	Output
UPS-IND 1346	AC 208/120V, 60Hz, 3×50A DC 192V, 44A	AC 208/120V, 60Hz, 3×27.8A,10KVA, 8KW
UPS-IND 1350	AC 208/120V, 60Hz, 3×75A DC 192V, 66A	AC 208/120V, 60Hz, 3×41.7A,15KVA, 12KW
UPS-IND 1353	AC 208/120V, 60Hz, 3×82.5A DC 192V, 114.6A	AC 208/120V, 60Hz, 3×55.6A,20KVA, 16KW
UPS-IND 1358	AC 208/120V, 60Hz, 3×124A DC 192V, 138A	AC 208/120V, 60Hz, 3×83.3A,30KVA, 24KW
UPS-IND 1362	AC 200-220V, 50/60Hz, 3×166A DC 360V, 97A	AC 200/208/220V, 50/60Hz, 40KVA, 32KW
UPS-IND 1366	AC 200-220V, 50/60Hz, 3×205A DC 360V, 121A	AC 200/208/220V, 50/60Hz, 50KVA, 40KW
UPS-IND 1370	AC 200-220V, 50/60Hz, 3×243A DC 360V, 145A	AC 200/208/220V, 50/60Hz, 60KVA, 48KW
UPS-IND 1376	AC 200-220V, 50/60Hz, 311A DC 348V, 198A	AC 200/208/220V, 50/60Hz, 80KVA, 64KW
UPS-IND 1378	AC 200-220V, 50/60Hz, 385A DC 348V, 247A	AC 200/208/220V, 50/60Hz, 100KVA, 80KW

